



BID BULLETIN No. 20-14

Project: Finishing of Communication Arts Building, MMSU, City of Batac

ABC: P4,820,230.80

Subject: Clarification on the Technical Specifications, Additional Scope of Works and Schedule of Opening of Bids

Notice is given to all interested bidders of the following clarifications, additional works and new schedule of opening of bids:

1. TILE WORKS

This work also includes resizing/adjustment of doors for the adjustment of flooring level because of tile installation. A total of 42 units of doors shall be resized/adjusted.

Tile shall be glazed Granite tile except for stairs. Use Semi-Glazed Granite Tile for stair tiles as mentioned in the blank form. Prior to purchasing of such, the Contractor is advised to show actual sample of tiles to the approving personnel/end-user of the University for Approval. The university shall be the one to decide the color and style of tiles.

2. Ceiling Works:

The Contractor is advised to provide Ceiling Joint Mesh Tape for Ceiling Joints to prevent joint gap prior to application of masonry putty.

3. Opening of Bids Schedule

Opening of bids is re-scheduled on September 3, 2020; 2:00 PM.

For the guidance and information of all concerned.


AMI RUTH R. COCSON
Chair